

ORDINANCE NO. 1036

Amending a section of Code of Ordinances, Chapter 15, Article 2; 15-205  
(Prior ordinance No. 764)

**An ordinance amending the approved materials for plumbing materials used for water pipe and other fixtures.**

Therefore, be it ordained by the Governing Body of the City of Smith Center, Kansas, in regular session assembled:

Section 1. That Ordinance No. 15-205 (Ord. 764), be amended, respectively, to read as follows;


“Section (n). ... “All service pipes shall be out of cast or galvanized iron, type K copper, or Copper Tube size polyethylene pipe (CTS poly) at the option of the City; provided that, copper goosenecks may be used to connect the corporation caulk to the service pipe.”...

“Section (o). ... “All plastic pipe used within the city shall be inspected and approved by the City Superintendent. Further, only brass fittings shall be used to connect water pipes to the curb stop.”


Section 2. That all other language from Ordinance No. 15-205 remain in full force and effect.

Section 3. That this ordinance be in full force from and after its publication in the official city paper, unless one or more interested parties file a written protest before expiration of such time.

Passed by the Council and approved by the Mayor this 11 day of July, 2022.

  
Bryce Wiehl  
Mayor

ATTEST:

  
Jill Conaway  
City Clerk

Passed: 07-11-2022

Effective: 07-21-2022